### (Certified English Translation)



Lauenburger Str. 65-67 – 21502 Geesthacht Fachbereich Wasser- und Umweltanalytik<sup>2</sup>



WEBAC-Chemie GmbH Fahrenberg 22 22885 Barsbüttel near Hamburg

Geesthacht, 2 August 2021

## Test Certificate according to KTW recommendations (Federal Health Gazette 20, 1977ff)

(This test was implemented in accordance with the requirements of the KTW recommendation of 1977, status October 2008.) Note: The Umweltbundesamt (UBA)<sup>3</sup> replaced the KTW guideline by the "Evaluation criteria for plastics and other organic materials in contact with drinking water (KTW-BWGL)" in March 2021.

Applicant:

Sworn Trans

WEBAC-Chemie GmbH

Fahrenberg 22 22885 Barsbüttel

Germany

Product:

WEBAC® 155

1C PU Combination Injection Resin

Test type:

**Product Testing** 

According to the test report of 2 August 2021, **laboratory number U-21-04947-001**, the test samples of **WEBAC**® **155** provided fulfill the requirements for use in potable water applications according to the KTW recommendations of the Bundesgesundheitsamt<sup>4</sup>, status October 2008, for the following

Application Range(s):

Temperature Range(s):

	Cold water	Warm water	Hot water
A Pipes			
B Containers			
C Equipment gear			
D1 Large-surface sealants	fulfilled		
D2 Other sealants and adhesives			

if the material is suitable for these in technical terms.

**Head of Department:** 

(signature)

(Dr. S.Dageförde)

The validity of this report is 5 years from the date of issue and can be extended once for a further 5 years after expiry.



<sup>1</sup> Central Laboratory

<sup>&</sup>lt;sup>2</sup> Dept. of Water and Environmental Analysis

<sup>&</sup>lt;sup>3</sup> German Environment Agency

<sup>&</sup>lt;sup>4</sup> Federal Ministry of Health

### (Certified English Translation)

# LADR Zentrallabor

Dr. Kramer & Kollegen

Lauenburger Str. 65-67 – 21502 Geesthacht Fachbereich Wasser- und Umweltanalytik<sup>6</sup>

Tel.: (+49) 4152 803-0 Fax: (+49) 4152 803-351 Email: wasser@ladr.de

WEBAC-Chemie GmbH Fahrenberg 22 22885 Barsbüttel near Hamburg

Geesthacht, 2 August 2021

### **Test Report**

(This test was implemented in accordance with the requirements of the KTW recommendation of 1977, status October 2008.) Note: The Umweltbundesamt (UBA)<sup>7</sup> replaced the KTW guideline by the "Evaluation criteria for plastics and other organic materials in contact with drinking water (KTW-BWGL)" in March 2021.

Laboratory No.:

U-21-04947-001

KTW classification:

D1 "large-surface sealants"

Manufacturer: Type of product:

WEBAC Chemie 1C PU Combination O/V<sup>8</sup> ratio:

1:25 cm<sup>2</sup>/cm<sup>3</sup>

duct: 1C F

Test sample surface:

87.9 cm<sup>2</sup>

Name of sample: Injection Resin WEBAC® 155

WEBAC® 155 Test water volume:

2199 ml

#### Test results:

Parameter	Day 1-3	Day 4-6	Day 7-9	KTW requirement after 9 days
рН	8.48	8.52	8.53	<b>6.5-9.5</b> DIN 38404 C5
Color (436 nm) 1/m	< 0.10	< 0.10	< 0.10	n.n.b. (≤0.5 for 436 nm) DIN EN ISO 7887
Turbidity TE/F	0.10	< 0.10	< 0.10	n.n.b. (≤1.5) DIN EN ISO 7027
Tendency to foam formation	n.n.b.	n.n.b.	n.n.b.	n.n.b.
Threshold odor number (20°C)	1	1	1	≤2
TOC (mg C/m²*day)	75.1	49.4	37.8	≤ <b>60</b> DIN EN 1484
Oxidation reaction with chlorine (mg Cl <sub>2</sub> /m <sup>2*</sup> day)	8.2	5.8	5.8	≤ <b>75</b> DIN EN ISO 7393-2

n.n.b. = no detectable influence

### Assessment:

The test samples of **WEBAC**<sup>®</sup> **155** you provided fulfill the requirements for use in potable water applications according to the KTW recommendations of the Bundesgesundheitsamt<sup>9</sup>, status October 2008, for application range D1 "large-surface sealants" (O/V ratio 1:25 cm²/cm³). No aromatic amines were quantitatively detectable.

**Head of Department:** 

(signature)

(Dr. S.Dageförde)

The validity of this report is 5 years from the date of issue and can be extended once for a further 5 years after expiry.

In my capacity as a public translator for the English language, duly commissioned and sworn by the President of the Regional Court of Heidelberg (Landgericht Heidelberg), I hereby confirm that the foregoing is a true and complete translation of the German document submitted to me in the original.

Heidelberg, Germany

9 August 2021

<sup>&</sup>lt;sup>5</sup> Central Laboratory

<sup>&</sup>lt;sup>6</sup> Dept. of Water and Environmental Analysis

<sup>&</sup>lt;sup>7</sup> German Environment Agency

<sup>8</sup> surface/volume

<sup>&</sup>lt;sup>9</sup> Federal Ministry of Health